CITY OF SAN DIEGO

Public Utilities Department

Wastewater Treatment and Disposal Division

Operation Support Group

Biosolids Certification Package
May 1, 2019 – May 31, 2019

Contents:

Title 22 analysis page.

40 CFR 503 certification for inorganic pollutant concentrations and limits.

Metropolitan Biosolids Center "Class B" Certification statement as per U.S. EPA 40 CFR Part 503 Standards For the Use and Disposal of Bulk Sewage Sludge.

Point Loma Wastewater Treatment Plant "Class B" Certification statement as per U.S. EPA 40 CFR Part 503 Standards For the Use and Disposal of Bulk Sewage Sludge.

Fractional Volatile Solids Reduction (FVSR) and VAR Certification statement.
- FVSR calculations page
- Raw and digested TVS data page

CITY OF SAN DIEGO
PUBLIC UTITLITIES DEPARTMENT

BIOSOLIDS CERTIFICATION STATEMENT
for
MEETING PATHOGEN REDUCTION REQUIREMENTS
May 1, 2019 – May 31, 2019

The following pathogens reduction requirement has been prepared in accordance with U.S. Environmental Protection Agency 40 CFR Part 503 Standards for the use and disposal of bulk sewage sludge from the Metro Biosolids Center Operated by the City of San Diego, Public Utilities Department.

503.17 (a)(4)(i)(C) - A description of how the Class B pathogens requirement in 503.32 (b) (3) is met.

At the City of San Diego Metropolitan Biosolids Center sludge undergoes anaerobic, high rate, mesophilic digestion that meets 503 regulations for detention time and temperature.

503.17 (a)(4)(i)(B) - Certification statement for meeting pathogens reduction requirements.

I certify, under penalty of law, that the Class B pathogen requirements in 503.32 (b)(3) have been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the pathogen requirements have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment.

For The City of San Diego
Public Utilities Department

By: R Pitchford Date 7/22/19

Richard Pitchford
Superintendent
Wastewater Treatment and Disposal Division
Metropolitan Biosolids Center

CITY OF SAN DIEGO
PUBLIC UTILITIES DEPARTMENT

BIOSOLIDS CERTIFICATION STATEMENT
for
MEETING PATHOGEN REDUCTION REQUIREMENTS
May 1, 2019 – May 31, 2019

The following pathogens reduction requirement has been prepared in accordance with U.S. Environmental Protection Agency 40 CFR Part 503 Standards for the use and disposal of bulk sewage sludge from the Metro Biosolids Center Operated by the City of San Diego, CA, Public Utilities Department.

503.17 (a)(4)(i)(C) - A description of how the Class B pathogens requirement in 503.32 (b) (3) is met.

At the City of San Diego Point Loma Wastewater Treatment Plant sludge undergoes anaerobic, high rate, mesophilic digestion that meets 503 regulations for detention time and temperature.

503.17 (a)(4)(i)(B) - Certification statement for meeting pathogens reduction requirements.

I certify, under penalty of law, that the Class B pathogen requirements in 503.32 (b)(3) have been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the pathogen requirements have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment.

For The City of San Diego
Public Utilities Department

By: _____ Date 7/31/19

David Marlow
Superintendent
Wastewater Treatment and Disposal Division
Point Loma Wastewater Treatment Plant

CITY OF SAN DIEGO
PUBLIC UTILITIES DEPARTMENT
CERTIFICATION STATEMENT

In Compliance with
U.S. Environmental Protection Agency 40 CFR Part 503 Standards
For the Use and Disposal of Bulk Sewage Sludge from the
Metro Biosolids Center
Operated by the City of San Diego Public Utilities Department

VECTOR ATTRACTION REDUCTION

The daily fractional volatile solids reduction (FVSR) values were calculated using the Van Kleck Equation and raw and digested sludge volatile solids for the month of May 2019 from locations based on the following information from Operations staff:

All sludge sent to Metro Biosolids Center (MBC) from the Pt. Loma WWTP is pumped from Digester 7.
Only North City Water Reclamation Plant (NCWRP) raw sludge is going to MBC digesters.
The MBC thickened sludge samples are representative of the raw sludge from NCWRP.
MBC is using Digester No.1 for sludge processing.

The following determinations of volatile solids were done using approved methods by a laboratory certified by the State of Arizona (Cert. No. AZ0783)

61.1 % Average Volatile Solids Reduction for the Pt. Loma WTP sludge digestion process.
58.1 % Average Volatile Solids Reduction for the sludge MBC treats from the NCWRP.

Both streams **do** / ~~do not~~ meet 38% FVSR criteria.

_____ Date 6/27/19
Environmental Chemistry Laboratory Senior Chemist

I certify that the sludge samples taken and used in these determinations were taken and handled under my direction and supervision using approved methods and are representative samples of actual operational conditions.

_____ 7/22/19
Wastewater Treatment Superintendent Date
Metro Biosolids Center (MBC)

_____ 7/31/19
Wastewater Treatment Superintendent Date
Pt. Loma Wastewater Treatment Plant

CERTIFICATION STATEMENT
VECTOR ATTRACTION REQUIREMENTS

I certify, under penalty of law, the vector attraction reduction requirement in Paragraph 503.33 (b) (1) which states that:
The mass of volatile solids in the sewage sludge shall be reduced by a minimum of 38 percent, has been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the vector reduction requirements have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment.

By: _____ 8/1/19
Chief Plant Operator Date
Wastewater Treatment and Disposal

Y:\EMTS\41.SECTIONS\WCS\REPORTS\MBC\VAR\2019\FVSR MAY 2019.DOCX

FVSR (Fractional Volatile Solids Reduction)

$$FVSR = \frac{VS_p - VS_b}{VS_p - (VS_p * VS_b)} = \frac{Vol.solidsRaw - Vol.solids\ Digested}{Vol.solids\ Raw - (Vol.solids\ Raw * Vol.solids\ Digested)}$$

Where: VS_p = Volatile Solids Feed Sludge (RAW SLUDGE),
VS_b = Volatile Solids Digested Sludge (DIG SLUDGE), currently only digester 7 is used for the calculation.

Volatile Solids (VS) is expressed as fractional numbers.

Average Volatile Solids for May 2019

Average %TVS Digested Sludge (Digester 7) for the month.	Average Raw (feed) sludge %TVS for the month	Calculated FVSR (%)
CA Lab data used	CA Lab data used	CA Lab data used
60.9	80.0	61.1%

Average Volatile Solids for MAY 2019

Average %TVS Digested Sludge (MBC Dig 1) for the month.	Average Raw (feed) sludge (MBC_TSBTC) %TVS for the month	Calculated FVSR (%)
CA Lab data used	CA Lab data used	CA Lab data used
68.1	83.6	58.1%

Y:\EMTS\41.Sections\WCS\GROUPS\PUBLIC\METALS\TS_VS_DSLDG\19135TS04

ALVARADO WASTEWATER CHEMISTRY LAB.
ARIZONA DH No. AZ0783
Total and Volatile Solids

BATCH ID: 19135TS04 ANALYSIS DATE: 5/15/2019 PROTOCOL: SM2540G/EPA160.4
ANALYSIS: TS/VS_SLDG MDL(%): 0.24
ANALYST: TJCANNON LCS TRUE VALUE: 3.9

SAMPLE ID	SAMPLE DATE	SOURCE	TEST TYPE	DISH ID	TARE WT grams	WET WT grams	INITIAL WT (g)	HOUR	FINAL WT (g)	HOUR	% TS	COMMENTS
Standard Methods 2540B for the Determination of Residue (%TS)												
P1094492	5/15/2019	LAB	BLNK	NONE	77.26	112.07	77.25	7:34 AM	77.25	9:45 AM	ND	
P1094494	5/15/2019	LAB	LCS	PB	74.99	113.97	76.51	7:34 AM	76.51	9:45 AM	3.9	%REC= 100
P1090823	5/14/2019	MBC_DIG1		XM	81.97	120.75	82.65	7:34 AM	82.65	9:45 AM	1.8	
P1090823	5/14/2019	MBC_DIG1	DUP	S6	75.59	122.74	76.44	7:34 AM	76.44	9:45 AM	1.8	%RPD =0
P1090822	5/14/2019	MBC_TSBTC		RAW	75.09	111.39	76.55	7:34 AM	76.55	9:45 AM	4	
P1090826	5/14/2019	PLDIG7		6	72.36	113.41	73.23	7:34 AM	73.23	9:45 AM	2.1	
P1090825	5/14/2019	RAW COMP		CR	80.45	122.27	82.05	7:34 AM	82.05	9:45 AM	3.8	
						FINAL WT (g)						
EPA Method 160.4 for %TVS at 550°C					TARE WT (g)	Total Solids	INITIAL WT (g)	HOUR	FINAL WT (g)	HOUR	**% TVS**	
P1094492	5/15/2019	LAB	BLNK	NONE	77.26	77.25						
P1094494	5/15/2019	LAB	LCS	PB	74.99	76.51						
P1090823	5/14/2019	MBC_DIG1		XM	81.97	82.65	82.18	1:28 PM	82.18		69.1	
P1090823	5/14/2019	MBC_DIG1	DUP	S6	75.59	76.44	75.87	1:28 PM	75.87		67.1	%RPD =2.9
P1090822	5/14/2019	MBC_TSBTC		RAW	75.09	76.55	75.33	1:28 PM	75.33		83.6	
P1090826	5/14/2019	PLDIG7		6	72.36	73.23	72.71	1:28 PM	72.7		60.9	
P1090825	5/14/2019	RAW COMP		CR	80.45	82.05	80.77	1:28 PM	80.77		80	

Denali_007075

1st Entry_____ 2nd Entry_____ Final Entry_____

POINT LOMA WASTEWATER TREATMENT PLANT
CALIFORNIA HAZARDOUS WASTE IDENTIFICATION TESTS (Title 22)
Metro Biosolids Center Dewatered Sludge
From 01-MAY-2019 to 31-MAY-2019

Source: MBCDEWCN
Sample ID: P1095098
Sample Date: 31-MAY-19

Constituent	MDL.	Units	Total Dry Wt. mg/Kg	Total Wet Wt. mg/Kg	TTLC Wet Wt. mg/Kg	W.E.T. Wet Wt. mg/L	STLC Wet Wt. mg/L	40 CFR 503 Limits ** mg/Kg	CA Health & Safety code Limits *** mg/Kg
Antimony	0.4	MG/KG	6.23	1.74	500	*	15.00		
Arsenic	1.33	MG/KG	2.57	0.72	500	*	5.00	41	
Barium	0.46	MG/KG	303	84.8	10000	*	100.00		
Beryllium	0.1	MG/KG	ND	ND	75	*	0.75		
Cadmium	0.1	MG/KG	0.94	0.262	100	*	1.00	39	
Chromium (VI)			NA		500	NA	5.00		
Chromium	0.1	MG/KG	48.9	13.7	2500	*	560.00	1,200	
Cobalt	0.1	MG/KG	3.88	1.09	8000	*	80.00		
Copper	1.7	MG/KG	579	162	2500	*	25.00	1,500	2,500
Lead	0.2	MG/KG	12.3	3.4	1000	*	5.00	300	350
Mercury	0.059	MG/KG	0.73	0.204	20	*	0.20	17	
Molybdenum	0.1	MG/KG	16.0	4.48	3500	*	350.00		
Nickel	0.1	MG/KG	25.4	7.11	2000	*	20.00	420	2,000
Selenium	0.93	MG/KG	5.43	1.52	100	*	1.00	100	
Silver	0.26	MG/KG	3.76	1.05	500	*	5.00		
Thallium	0.2	MG/KG	ND	ND	700	*	7.00		
Vanadium	0.1	MG/KG	23.3	6.52	2400	*	24.00		
Zinc	0.8	MG/KG	929	260	5000	*	250.00	2,800	
Fluoride	1	MG/KG	34.5	9.65	18000	*	180.00		
Sulfides-Reactive	11	MG/KG	23.0	6.0					
Sulfides-Total	500	MG/KG	6700	1880					
Total Solids		WT%	28.0						
Total Volatile Solids		WT%	62.0						
pH		PH	8.06		>2 - <12				
Ammonia-N	28	MG/KG	7830						
Nitrite Nitrate Calc		MG/KG	38.1						
Organic Nitrogen Calc.		MG/KG	43270						
Total Kjeldahl Nitrogen		MG/KG	51100						
Aldrin	0.0013	MG/KG	ND	ND	1.4	*	0.14		
Chlordanes	0.0016	MG/KG	ND	ND	2.5	*	0.25		
DDT, DDE, DDD	0.0023	MG/KG	ND	ND	1.0	*	0.10		
Dieldrin	0.0006	MG/KG	0.01	0.002	8.0	*	0.80		
2,4-D	0.19	MG/KG	ND	ND	100	*	10.00		
Endrin	0.0011	MG/KG	ND	ND	0.2	*	0.02		
Heptachlor	0.0013	MG/KG	ND	ND	4.7	*	0.47		
Kepone			NA	NA	21	NA	2.10		
Lindane	0.953	MG/KG	ND	ND					
BHC, Total	0.0017	MG/KG	ND	ND	4.0	*	0.40		
Methoxychlor	0.0027	MG/KG	ND	ND	100	*	10.00		
Mirex	0.0038	MG/KG	ND	ND	21	*	2.10		
Pentachlorophenol	14	MG/KG	ND	ND	17	*	1.70		
PCBs (Arochlors)	2.39	MG/KG	ND	ND	50	*	5.00		
Toxaphene	0.17	MG/KG	ND	ND	5	*	0.50		
Trichloroethene	0.0217	MG/KG	ND	ND	2040	*	204.00		
2,4,5-TP	0.1	MG/KG	ND	ND	10	*	1.00		

On the basis of these analyses, I certify that this dried sludge is non-hazardous as defined by California Code, Title 22, Section 66699. All determinations were done using approved methods by laboratories certified by the State of Arizona (Cert. No. AZ0783).

Elvira Mercado, Senior Chemist, Environmental Chemistry Laboratory

TTLC = Total Threshold Limit Concentration.
STLC = Soluble Threshold Limit Concentration.
W.E.T. = Waste Extraction Technique.
* = The total wet concentration is less than 10 times the STLC. Therefore, by definition,
. this substance is present in concentration that is less than the limit for hazardous wastes.
** = Limits are in mg/Kg (dry weight) based on 40 CFR part 503.13 Table 3 "Limits for Land Application".
*** = The California State Health and Safety Code 25157.8 established a lower limit for Lead.
NA = Not Analyzed, ND= Not Detected, NS= Not Sampled, NR= Not Required
MDL = Method Detection Limit (mg/Kg per dry weight; except for pH and Total and Volatile Solids)
MBCDEWCN = Metro Biosolids Center Dewatered Centrifuged Sludge.

CERTIFICATION STATEMENT
In Compliance With
U.S. Environmental Protection Agency 40 CFR Part 503 Standards
For the Use and Disposal of Bulk Sewage Sludge from the
Metro Biosolids Center
Operated by the
City of San Diego Public Utilities Department

Monthly Sludge Composite Certification - *Centrifuge Dewatered Sludge*

I. INORGANIC POLLUTANT CONCENTRATIONS: The results of analyses below are for a composite sample of daily centrifuged dewatered sludge samples taken from the centrifuges over the calendar month of May 2019. All analyses were performed by the City of San Diego's Environmental Chemistry Services Laboratory using methods certified by the State of Arizona (Cert. No. AZ0783).

Metals from Table 3 of Paragraph 503.13†
(All concentrations in dry weight)

Parameter	Value	Units	503 Limit	Units
Arsenic	2.57	mg/Kg	41	mg/Kg
Cadmium	0.94	mg/Kg	39	mg/Kg
Chromium	48.9	mg/Kg	1,200	mg/Kg
Copper	579	mg/Kg	1,500	mg/Kg
Lead	12.3	mg/Kg	300	mg/Kg
Mercury	0.73	mg/Kg	17	mg/Kg
Molybdenum	16.0	mg/Kg	75	mg/Kg^
Nickel	25.4	mg/Kg	420	mg/Kg
Selenium	5.43	mg/Kg	100	mg/Kg
Zinc	929	mg/Kg	2,800	mg/Kg
Total Nitrogen#	5.11	Wt %		
Date of Sample	31-May-2019			
Total Solids	28.0	Wt %		
Volatile Solids	62.0	Wt %		

† Also conforms to Table 2-Monthly Average Pollutant Concentration of the Arizona Administrative Code Title 18, Chapter 9.
^ Limits for Molybdenum taken from 2009 version of 40 CFR part 503.13 Table 1, Ceiling Concentrations
# Value is a sum calculation of Total kjeldahl nitrogen, Nitrate as N and Nitrite as N.

Based on this month's analysis and the results of analyses of monthly sludge composite samples for the previous year, no parameter in the described sludge stream exceeds 40 CFR Part 503 Standards for land application.

Senior Chemist
Environmental Chemistry Laboratory,
California State ELAP Cert. No. 1609

6/27/19
Date

VAR CERT. Form
Revised 7/6/2000

CERTIFICATION STATEMENT
In Compliance With
U.S. Environmental Protection Agency 40 CFR Part 503 Standards
For the Use and Disposal of Bulk Sewage Sludge from the
Metro Biosolids Center
Operated by the
City of San Diego Public Utilities Department

Monthly Sludge Composite Certification - *Centrifuge Dewatered Sludge*

I. INORGANIC POLLUTANT CONCENTRATIONS: The results of analyses below are for a composite sample of daily centrifuged dewatered sludge samples taken from the centrifuges over the calendar month of May 2019.

Metals from Table 3 of Paragraph 503.13†
(All concentrations in dry weight)

Parameter	Value	Units	503 Limit	Units
Arsenic	ND	mg/Kg	41	mg/Kg
Cadmium	ND	mg/Kg	39	mg/Kg
Chromium	50	mg/Kg	1,200	mg/Kg
Copper	630	mg/Kg	1,500	mg/Kg
Lead	DNQ4.0	mg/Kg	300	mg/Kg
Mercury	0.73	mg/Kg	17	mg/Kg
Molybdenum	19	mg/Kg	75	mg/Kg^
Nickel	23	mg/Kg	420	mg/Kg
Selenium	DNQ6.3	mg/Kg	100	mg/Kg
Zinc	970	mg/Kg	2,800	mg/Kg
Total Nitrogen*	5.11	Wt %		
Date of Sample	31-May-2019			
Total Solids	28.0	Wt %		
Volatile Solids	62.0	Wt %		

† Also conforms to Table 2-Monthly Average Pollutant Concentration of the Arizona Administrative Code Title 18, Chapter 9.
^ Limits for Molybdenum taken from 2009 version of 40 CFR part 503.13 Table 1, Ceiling Concentrations
* Value is a sum calculation of Total kjeldahl nitrogen, Nitrate as N and Nitrite as N.
6010B parameters (As, Cd, Cr, Cu, Pb, Mo, Ni, Se and Zn) were analyzed by TestAmerica.
DNQ = Detected but not quantified. Sample result is less than minimum level but greater than or equal to MDL.

Based on this month's analysis and the results of analyses of monthly sludge composite samples for the previous year, no parameter in the described sludge stream exceeds 40 CFR Part 503 Standards for land application.

(COA) 7/1/2019

Senior Chemist
Environmental Chemistry Laboratory,
California State ELAP Cert. No. 1609

Date

VAR CERT. Form
Revised 7/6/2000

POINT LOMA WASTEWATER TREATMENT PLANT
CALIFORNIA HAZARDOUS WASTE IDENTIFICATION TESTS (Title 22)
Metro Biosolids Center Dewatered Sludge
From 01-MAY-2019 to 31-MAY-2019

Source: MBCDEWCN
Sample ID: P1095098
Sample Date: 31-MAY-19

Constituent	MDL.	Units	Total Dry Wt. mg/Kg	Total Wet Wt. mg/Kg	TTLC Wet Wt. mg/Kg	W.E.T. Wet Wt. mg/L	STLC Wet Wt. mg/L	40 CFR 503 Limits ** mg/Kg	CA Health & Safety code Limits *** mg/Kg
Antimony	17	MG/KG	ND	ND	500	*	15.00		
Arsenic	5.1	MG/KG	ND	ND	500	*	5.00	41	
Barium	0.37	MG/KG	300	84	10000	*	100.00		
Beryllium	0.85	MG/KG	ND	ND	75	*	0.75		
Cadmium	0.85	MG/KG	ND	ND	100	*	1.00	39	
Chromium (VI)			NA		500	NA	5.00		
Chromium	1.7	MG/KG	50	14	2500	*	560.00	1,200	
Cobalt	1.7	MG/KG	ND	ND	8000	*	80.00		
Copper	3.7	MG/KG	630	176	2500	*	25.00	1,500	2,500
Lead	3.4	MG/KG	DNQ4.0	DNQ1.1	1000	*	5.00	300	350
Mercury	0.059	MG/KG	0.73	0.204	20	*	0.20	17	
Molybdenum	3.4	MG/KG	19	5.32	3500	*	350.00		
Nickel	3.4	MG/KG	23	6.44	2000	*	20.00	420	2,000
Selenium	5.8	MG/KG	DNQ6.3	DNQ1.76	100	*	1.00	100	
Silver	3.0	MG/KG	DNQ3.3	DNQ0.92	500	*	5.00		
Thallium	17	MG/KG	ND	ND	700	*	7.00		
Vanadium	1.7	MG/KG	24	6.72	2400	*	24.00		
Zinc	8.5	MG/KG	970	272	5000	*	250.00	2,800	
Fluoride	1	MG/KG	34.5	9.65	18000	*	180.00		
Sulfides-Reactive	11	MG/KG	23.0	6.0					
Sulfides-Total	500	MG/KG	6700	1880					
Total Solids		WT%	28.0						
Total Volatile Solids		WT%	62.0						
pH		PH	8.06		>2 - <12				
Ammonia-N	28	MG/KG	7830						
Nitrite Nitrate Calc		MG/KG	38.1						
Organic Nitrogen Calc.		MG/KG	43270						
Total Kjeldahl Nitrogen		MG/KG	51100						
Aldrin	0.0013	MG/KG	ND	ND	1.4	*	0.14		
Chlordanes	0.0016	MG/KG	ND	ND	2.5	*	0.25		
DDT, DDE, DDD	0.0023	MG/KG	ND	ND	1.0	*	0.10		
Dieldrin	0.0006	MG/KG	0.01	0.002	8.0	*	0.80		
2,4-D	0.19	MG/KG	ND	ND	100	*	10.00		
Endrin	0.0011	MG/KG	ND	ND	0.2	*	0.02		
Heptachlor	0.0013	MG/KG	ND	ND	4.7	*	0.47		
Kepone			NA	NA	21	NA	2.10		
Lindane	0.953	MG/KG	ND	ND					
BHC, Total	0.0017	MG/KG	ND	ND	4.0	*	0.40		
Methoxychlor	0.0027	MG/KG	ND	ND	100	*	10.00		
Mirex	0.0038	MG/KG	ND	ND	21	*	2.10		
Pentachlorophenol	14	MG/KG	ND	ND	17	*	1.70		
PCBs (Arochlors)	2.39	MG/KG	ND	ND	50	*	5.00		
Toxaphene	0.17	MG/KG	ND	ND	5	*	0.50		
Trichloroethene	0.0217	MG/KG	ND	ND	2040	*	204.00		
2,4,5-TP	0.1	MG/KG	ND	ND	10	*	1.00		

On the basis of these analyses, I certify that this dried sludge is non-hazardous as defined by California Code, Title 22, Section 66699.

Elvira Mercado, Senior Chemist, Environmental Chemistry Laboratory

TTLC = Total Threshold Limit Concentration.
STLC = Soluble Threshold Limit Concentration.
W.E.T. = Waste Extraction Technique.
* = The total wet concentration is less than 10 times the STLC. Therefore, by definition, this substance is present in concentration that is less than the limit for hazardous wastes.
** = Limits are in mg/Kg (dry weight) based on 40 CFR part 503.13 Table 3 "Limits for Land Application".
*** = The California State Health and Safety Code 25157.8 established a lower limit for Lead.
NA = Not Analyzed, ND= Not Detected, NS= Not Sampled, NR= Not Required
MDL = Method Detection Limit (mg/Kg per dry weight; except for pH and Total and Volatile Solids)
MBCDEWCN = Metro Biosolids Center Dewatered Centrifuged Sludge.
DNQ = Detected but not quantified. Sample result is less than minimum Level but greater than or equal to MDL.
6010B metal parameters were analyzed by TestAmerica.